

APPLICATION No.: 6776

TAP CLEARED

LOCATION: 50 Katherine St.

OWNER: Donald Cosme

MEASURES: 1/2"

H lead

June 8, 1891

W from

County St. ? 460.7 ft.

N from S line

Katharine St. 9.1 ft.

E from W line

house 3.6 ft.

10/21/09 - City crew renewed service from main to property line

17 ft - 3/4" copper tubing; 1 - 3/4" curb stop;
1 Caldwell stop box; 1 - 3/4" lead to cop adapt xs;
1 - 5/8" x 3/4" Fig. 413; Tap reamed

Foreman: Danny Perry

3/6/17 renewed c/s to meter
1 ft cast iron curb stop boxes
1 ft 3/4" ball valve
1 ft 3/4" x 1/2" brass bushing
1 ft 3/4" 90* threaded copper
1 ft 3/4" female corp adapter
1 5 ft 3/4" copper tubing
lead worker - manny washburn dpi

DATE

BEF.

AFT.

REMARKS

10/21/09 9:30

2009-4305366

10-21-09

Tap reamed

[illegible]

CHARGE OUTS

[illegible]