

APPLICATION No.: 6780

TAP CLEARED

LOCATION: 202 Belleville Ave

OWNER: John B DeMello

31-313

MEASURES: 1/2" H lead

S from Sawyer 129.6ft
W from E line Belleville Ave 8.0ft
S from N line house 19.6ft
W from W line house 15.0ft

10/29/92 Belleville Ave. sewer proj. Gioioso Const. crimped
& cut serv. over 30" force main also pulled from curb stop

Renewed from curb stop to a point 7.4ft

Stock: 7.6ft 3/4" copper tubing 1-3/4x3/4 cop-cop cplg.comp

7.4ft W x curb stop Cont to maintain trench Insp M Rose III

=====

DATE

BEF.

AFT.

REMARKS

METER HISTORY

[illegible]

CHARGE OUTS

LOCATION: 202 Belleville Ave.

OWNER: John B. DeMello.

DATE

BEF.

AFT.

REMARKS

9/13/71

Reamed

MEASURES: $\frac{1}{2}$ "

H lead

June 13, 1891

S from

Sawyer

~~127.5 ft.~~

129.6 ft.

W from E line

Belleville Ave.

~~8.0 ft.~~

8.0 ft.

S from N line

House

~~19.6 ft.~~

19.6 ft.

W x W line

House

15.0 ft.

Sept. 13, 1971 Renewed from main to a point 4 ft. from main.

4 ft. - $\frac{3}{4}$ " Copper tubing 1 wipe joint $\frac{3}{4}$ x $\frac{3}{4}$ H ays Fig. 413- - -Nov. 12, 1973 Renewed from $\frac{1}{2}$ ft. inside curb stop to inside cellar.15 ft. - $\frac{3}{4}$ " Copper tubing $\frac{3}{4}$ " x $\frac{5}{8}$ " copper to lead adaptor

7/9/76: Due to the inst. of the new 48" main this service has been renewed from the main to 21 ft. from the main. Stock supp. & inst. by Zoppo; 1" Corporation Ford compression; 1" x $\frac{3}{4}$ " Reducer; 21 ft. - $\frac{3}{4}$ " copper tubing; $\frac{3}{4}$ " curb stop Ford Compression; $\frac{3}{4}$ " x $\frac{5}{8}$ " lead to copper adapt. XKS; Measures of 1" Corporation: N x N line Beetle St.

102.4 ft. - W x E line Belleville Ave. 29.0 ft.

24 12 92

[illegible]

2.