

APPLICATION No.: 6797

TAP CLEARED

LOCATION: 132 Washington

OWNER: A H Coe Jr.

MEASURES: 5/8"

E from	Orchard	55.8 ft.
N from S	Washington	6.9 ft.
E from W -	house	1.1 ft.

June 20, 1977: Renewed from main to point 4 ft. inside curbstop.
10 ft.-3/4" copper; 5/8" x 3/4" Fig. 413; tap reamed; 3/4" curbstop;
stop box; 5/8" x 3/4" lead connector XS;

Jan. 14, 1993 No leak found - leak was at 133 Washington St.
St. cut: 3' x 6' Warr..

2/10/06 NOTE: FOUND COPPER FROM MAIN TO PROPERTY LINE

12/5/06 Cont. Joseph August renewed from 4.6 ft. South of curb stop to inside cellar. See attached drawing. Insp: P Reynolds

[illegible]

CHARGE OUTS

Renewed From 4.6' South of c/s
To inside cellar

↑
N

