

APPLICATION No.: 6861

TAP CLEARED

LOCATION: 95 Bonney St.

OWNER: Ernest T. Silva

MEASURES: 5/8" H lead July 25, 1891

S from Washington St. 216.5 ft.

E from W line Bonney St. 6.8 ft.

S from N line house 11.0 ft.

May 17, 1995: Renewed from main to ins. cellar ( 8 ft ins. prop line)

Stock: 22 ft 3/4" copper tubing 1-3/4" curb stop

1- Caldwell stop box 1-3/4x5/8 Fig 413

=====

12/23/03 413 on 5/8" tap leaking Stock: 5/8" x 3/4" Fig. 413

Tap reamed

-----

DATE

BEF.

AFT.

REMARKS

Dig safe # 952604021

5/17/95: tap reamed

12/23/03 830 AM 2003-520-1391

12/23/03

Tap reamed

## METER HISTORY

## CHARGE OUTS

[illegible]