

6866

~~76 - Durfee~~

Bonjamin Baldrion

BEF.

AFT.

REMARKS

7/4/03

4 ро.

EXPIRED

2002-280-2457

8/14/02

10 am

2002-330-5355

3/4 "

E form	Bullock	73.6
--------	---------	------

N from S line Durfee 6.2

E from W line	House	2.1
---------------	-------	-----

May 14, 1958 Renewed from curb stop to a point 2 ft. inside curb
stop 2 ft. of 3/4" copper tubing
2 lbs. wiping solder

March 26, 1974: Relocated service from 8" main to new 12" main.
Renewed from main to 1 ft. inside curb stop. 14.5 ft.-3/4" copper;
3/4" corp.; 3/4" curb stop; stop box;

Oct. 2, 1995: Service pulled while digging hole for 75 Durfee St
Renewed from main to a point 1.8ft

Stock: 1.8ft 3/4" copper tubing 1-3/4x3/4 cop-cop cplg.comp
1- 1"x3/4" Fig 413 1-1" corporation tap 1-12"x1" service saddle

August 14, 2002: Renewed from main to a point 3 ft in front of the main; 3 ft. - 1" copper tubing; 1 - 1" x 3/4" compression cplg. to leas to cop. adapt. XXS; 1 - 1" x 1" Fig. 413; tap reamed

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 6866

LOCATION: 76 Durfee Street

OWNER:

31-313

MEASURES:

August 21, 2002: Renewed from curb stop to inside cellar (6 ft.ins. prop. line); 12 ft. - 3/4" copper tubing; 1 - 3/4" curb stop' 1-Caldwell Stop Box

TAP CLEARED

[illegible]

[illegible][illegible]