

APPLICATION No.: 6870

TAP CLEARED

LOCATION: 26 Rounds

OWNER: E H Gifford

MEASURES:

5/8"

N from

Middle

71.1 ft.

W from E line

Rounds

6.5 ft.

N from S line

House

12.1 ft.

8/29/94: Biszko Cont. renewed from newly installed 8" ductile
main on Rounds St. to property line All stock supplied by
contractor 24.0ft 3/4" copper tubing 1-3/4" curb stop
1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xs 1-3/4" corporation
tap Insp. F Bento =====

Oct. 5, 1995 leak ins bldg Souto 8 ft. punch - Told owner to call plumber - has sump pump

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]