


APPLICATION No.: 6873TAP CLEARED LOCATION: 75 Shawmut Ave.OWNER: Thomas QuintinMEASURES: 3/4"*Copper*

01-01-1891

N from

Parker

194.9 ft.

E from W line

Shawmut Ave.

6.7 ft.

S from N line

House

7.0 ft.

June 19, 1972 Renewed from $\frac{1}{2}$ ft. outside curb stop to property line
 $8\frac{1}{2}$ ft. of $\frac{3}{4}$ " copper tubing 1 $\frac{3}{4}$ " curb stop Hays
2 wipe joints

MAY 18 1982 --Tilcon renewed from the main to the curb
stop. 7.0 ft. - $\frac{3}{4}$ " copper; 1" x $\frac{3}{4}$ " Fig. 413;

12/15/10 - City crew tightened curb stop to repair leak
1 Caldwell stop box. Foreman: D. Farland

DATE

BEF.

AFT.

REMARKS

12/15/10 8:15

2010-5103041

[illegible]

CHARGE OUTS

[illegible]