

APPLICATION No.: 6880

TAP CLEARED

LOCATION: 141 Bonney St

OWNER: ✓

31-313

MEASURES:

Aug 1, 1891

N from Rockland St 42.9'

E from W Line Bonney St 7.2'

S from N line House 2.8'

1" COPPER

10-15-2018: Lead service line replacement program
phase 1, TYPE:CU, Diameter 1", Water Pressure 80

Contractor: P. Gioiosio & Sons

Distance from main to curb stop 7.5'

Distance curb stop to meter 24'

Distance from curb face to curb stop 1.0'

Depth of service 4.0'

Total length of new pipe installed 31.5'

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball Valve furnished: YES Size 1"

DATE

BEF.

AFT.

REMARKS

03-11-1983 Reamed

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

