

6914

TAP CLEARED

4 Waverly

Mrs. Emma Caton

5/8"

Allen

124.0 ft.

W from E	Waverly	6.7 ft.
----------	---------	---------

6.7 ft.

S from N	haverly	8.7 ft.
	house	4.1 ft.

4.1 ft.

November 18, 1974 Removed from the 4" main & tapped
into the 6" main.

2.8 ft. - 3/4" Copper tubing 3/4" Corporation
1 wipe joint

200 200 200

Jan. 6, 1975 Renewed from 6" outside curb stop to inside cellar.

15 ft. - 3/4" Copper tubing (6 ft. inside)
3/4" curb Stop Caldwell Stop Box

3/4" curb Stop Caldwell Stop Box

1 wipe joint

2000 2000 1999

Beb. 7, 1966 Rewiped joint at the main.

1 lb. wiping solder 1 5/8" reused corp. coupling

7/22/85: Renewed from main to a point 4ft.4in.

Stock: 4ft.4in. 3/4" copper tubing 1 3/4x5/8 lead to cop adapt xs

1 3/4x3/4 Fig. 413

=====

=====

[illegible]

CHARGE OUTS

APPLICATION No.: 6914

TAP CLEARED

LOCATION: 4 WAVERLY ST

OWNER: MRS. EMMA CATON

MEASURES: 5/8"

N FROM	ALLEN ST	124.0 ft
W FROM E	WAVERLY	6.7 ft
S FROM N	HOUSE	4.1 ft

April 18, 1997:

Renewed from main to curb stop

Stock: 16ft 3/4" copper tubing 1-3/4" curb stop

1- Caldwell stop box 1-3/4x3/4 Fig 413=====

11/3/97: renewed from main to a point 3 ft. Stock: 3 ft. 3/4"
copper tubing, 1- 3/4x3/4 cop. to cop. cplg., comp., 1- 3/4"
corporation tap =====

DATE

BEF.

AFT.

REMARKS

4/18/97: tap reamed

11/3/97

97 4500379.

[illegible]

CHARGE OUTS

[illegible]