

APPLICATION No.: 6974 $\frac{1}{2}$ " H lead

TAP CLEARED

LOCATION: 171 Belleville Ave.

OWNER: John Carlos

DATE

BEF.

AFT.

REMARKS

12/5/61

Reamed

MEASURES: N x N line Coggeshall St. 245.0 ft.
 $\frac{1}{2}$ " H lead Oct. 3, 1891
~~S from Beetle 158.8 ft.~~
 E from W line Belleville Ave. 8.2 ft. 7.6 ft.
 S from S line House 6.8 ft. 6.0 ft.
 E x E line House 11.6 ft.

Dec. 5, 1961 Renewed from main to a point 4 ft. from main.

4 ft. - $\frac{3}{4}$ " copper tubing; 1 Reused corp. cplg.;
 Tap reamed; 1# wiping solder
 - - -

July 10, 1962 Renewed from meter to a point 6 ft. from meter. Stock supplied & installed by owner's plumber,
 Miranda - - -

6/29/76: Due to the installation of the new 48" main this service has been renewed from the main to 9 ft. from the main. Stock supplied and installed by Zoppo. 1" Corporation Ford compression; 1" x $\frac{3}{4}$ " Reducer; 9 ft. - $\frac{3}{4}$ " copper; $\frac{3}{4}$ " Curb stop Ford compression; $\frac{3}{4}$ " x $\frac{5}{8}$ " lead to copper adapt. XKS;

Measures of 1" Corporation:

S x S line Beetle St. 160.0 ft.

E x W line Belleville Ave. 19.0 ft.

METER HISTORY

[illegible]

CHARGE OUTS