

7015

LOCATION: 16 Welcome St

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

OWNER:

11/16/62 Ream

31-313

W X McGurk St

140.6 ft

6/26/09 Ream

MEASURES:

N X S Welcome St

8.8 ft

E X W House

1.6 ft

1" Copper Service 11/16/2018

Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 22

Distance curb stop to meter (ft) 20

Distance from curb face to curb stop (ft) 1

Depth of service (ft) 3.5

Total length of new pipe installed (ft) 20

Curb stop replaced: No size 3/4"

Corporation replaced: No size 3/4"

Ball valve replaced: yes size 1"

Remarks: 1-3/4 union installed 1 LF outside curb stop

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

