

APPLICATION No.: 7072

TAP CLEARED

LOCATION: 70 Hall St

DATE

BEF.

AFT.

REMARKS

OWNER:

10/21/75 Ream

31-313

MEASURES: January 23, 1892

S X Rockland St 71.8 ft

W X E Line Hall St 6.4 ft

S X N Line House 3.1 ft

1" Copper Service

12/04/2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & SOn

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) 20

Distance from curb stop to meter (ft) 14

Distance from curb face to curb stop (ft) 2.3

Depth of service (ft) 3.8

Total length of new pipe installed (ft) 14

Curb stop replaced: no, size 3/4"

Corporation replaced: no size 3/4"

Ball valve furnished: yes size 1"

Remarks: 1-3/4" union installed 1LF outside
curb stop

[illegible]

CHARGE OUTS

