

APPLICATION No.: 7089

## TAP CLEARED

LOCATION: 505 Rivet St.

OWNER: Harry Wantman

**MEASURES:**

5/8" H lead Apr. 5, 1892

W from Hemlock St. 179.0 ft.

S from N line      Rivet St.      6.5 ft.

W from E line house 7.7 ft.

May 3, 1955 Renewed from tap to a point 1 ft. from tap.  
1 ft. of 3/4" copper tubing 1 3/4" cop. to I.F. cplg.  
1 wipe joint

October 22, 1970 Renewed from  $\frac{1}{2}$  ft. outside curb stop to inside cellar.

17 ft. of 3/4" copper tubing (10 ft. inside)  
1 3/4" Hays curb stop 1 wipe joint

12/7/94: Cont. #6 Biszko Cont.renewed from main to prop line  
during cement lining Cont.supplied all stock & will maintain  
trench 19ft 3/4" copper tubing 1-3/4" curb stop  
1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs  
1-3/4x5/8 Fig 413 Insp. F Bento

=====

BRADBURY-WARING, INC.

[illegible]

## CHARGE OUTS

[illegible]