

APPLICATION No.: 7106

TAP CLEARED

LOCATION: 128 County Street

DATE

BEF.

AFT.

REMARKS

OWNER:

MEASURES: $\frac{1}{2}$ "

(cont'd)

April 8, 1892

✓ -----
December 3, 1975 Replaced curb stop box.
Contractor broke box.
1 curb stop box, complete

[illegible]

CHARGE OUTS

APPLICATION No.: 20853

TAP CLEARED

874/-2521

LOCATION: 59-61 Rodney St.

DATE

BEF.

AFT.

REMARKS

OWNER: Joseph N. Camara, Ft Ux

12-22-2000 Tap reamed

MEASURES: 5/8" H lead Aug. 3, 1925

E from ^{OK} ~~ELECTRIC~~ Cleveland St.(N) 288.0 ft.

S from N line Rodney St. 8.2 ft.

E from W line house 3.9 ft.

10/08/87 Renewed from 1/2' outside curb stop to prop line
 Stock: 7ft-3/4 copper tubing, 1-3/4 curb stop
 1-Caldwell Stop box, 2-5/8x3/4 lead to cop adapt xxs

12-22-2000 Tilcon Const. renewed from main to curb stop. Stock:
 25 ft. - 3/4" Copper tubing, 1 - 3/4" x Curb Stop(same),
 1 - Caldwell Stop Box(same), 1 - 5/8"x 3/4" Fig. 413 Tilcon Const.
 to maintain cut.

11/29/2023 Contractor City of New Bedford
 Renewed Curb Stop to Meter
 MeterCou 5/8" Meter Coupling p-(5-8)" Units 2 UOM Each
 (3-4)" Ball 3/4" Ball Valve Units 1 UOM Each
 (3-4)" 3/4 PROPRESS 90 Units 2 UOM Each
 CI-CRB-B Cast Iron Curb Stop Boxes X Units 1 UOM each
 3/4" 3/4" Copper Tubing Type-K Units 22 UOM Feet
 FncoCxP-6" CLAY TO PVC 6 Units 2 UOM Each
 PvcP-6 PVC Pipe (13ft Lengths) Units 5 UOM Each

METER HISTORY

[illegible]

CHARGE OUTS