

APPLICATION No.: 7151 3/4"

TAP CLEARED 82180818

LOCATION: 500 Cottage St.

OWNER: F. McCarthy

MEASURES: 3/4"

N from

Parker

151.0 ft.

W from E line

Cottage

8.1 ft.

S from N line

Body of House

1.9 ft.

Feb. 24, 1958 Renewed from stop to a point  $2\frac{1}{2}$ ' inside curb stop  
 $2\frac{1}{2}$  ft. of 3/4" copper tubing 2 lbs. wiping solder

Aug. 26, 1969 Renewed from 1 ft. outside curb stop to property line  
 8' of 3/4" copper tubing 3/4" cop to cop. cplg., A-1525  
 3/4" cop. to cop. stop, fig. 415 R. H.  
 1 lb. wiping solder

Aug. 25, 1959 Renewed from property line to meter inside cellar  
 13 ft. of 3/4" copper tubing

MAY 6 - 1982 Repaired 2 ft. outside of main. 2.0 ft. - 3/4" cop.  
 3/4" x 3/4" Fig. 413; 5/8" x 3/4" lead-cop. adapt. XXS;

October 7, 2002: Renewed from main to curb stop; 25 ft. - 3/4" copper  
 tubing; 1 - 3/4" curb stop; 1 - caldwell stop box; 1 - 3/4 x 3/4  
 Fig. 413; tap reamed

DATE

BEF.

AFT.

REMARKS

MAY 6 - 1982

Reamed

## METER HISTORY

[illegible]

## CHARGE OUTS