

APPLICATION No.: 7162 3/4"

TAP CLEARED 8945-0039

LOCATION: 601 Brock Ave.

OWNER: Park Dept.

MEASURES:

3/4"

N from Clara 25.5 ft.

E from W line Brock Ave. 11.0 ft.

S from S line upper part of barn 8.2 ft.

April 1, 1966 Repaired leak near foundation of house in park.

1 ft. - 3/4" copper tubing; 2# wiping solder;

All digging and backfilling was done by the Park Dept.

- - -

April 23, 1969 Renewed from 6" outside of curb stop to the property line.

8 1/2 ft. - 3/4" copper tubing; 1-3/4" Mueller curb stop;
1 wipe joint; 1-1" x 3/4" fig. 413 lead to copper;

- - -

Oct. 20, 1970 Renewed from the curb stop to 1 ft. outside bldg.

70 ft. - 3/4" Copper tubing (60 ft. inside)

2 - 3/4" Copper cplg. (1 - 10 ft. W x curb box)
(1 - 1 ft. outside bldg.)

- - -

11/6/89: Renewed from main to curb stop

Stock: 10 ft. 3/4" copper tubing 1-3/4" curb stop

1-Caldwell stop box 1-3/4x3/4 Fig. 413

DATE

BEF.

AFT.

REMARKS

11/6/89: TAP REAMED

METER HISTORY

CHARGE OUTS

[illegible]