

APPLICATION No.: 7173

TAP CLEARED 8347-0006

LOCATION: 96 ~~St~~ Park

OWNER: Patk J. Norton

MEASURES: 5/8"

S from Union 257.2 ft.

W from E line Park 7.0 ft.

S from N line House 8.8 ft.

May 3, 1944 Leak near tap. No pipe.
-----Nov. 21, 1983 - Renewed from 1/2 ft. outside curb stop to
a point 4 ft. inside curb stop.

4 1/2 ft. - 3/4" copper tubing

1 - 3/4" curb stop 1 stop box

2 - 5/8" x 3/4" lead to copper adaptor XS
-----9-29-2000 Renewed from 3 ft. inside curb stop cop to cop
into cellar. Stock: 15ft. - 3/4" Copper tubing, 1 - 3/4"
x 3/4" cop to cop cplg., comp.

9-2000 Zenone Const. renewed from main to property line.

Stock: 23 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Sotp

1 - Cladwell Stop Box, 1 - 5/8"x3/4" lead to cop. adapt.XXS

1 - 5/8"x3/4" Fig. 413. Zenone Const. to maintain cut.

DATE

BEF.

AFT.

REMARKS

9-2000 Tap reamed

7/29/2000 2000 4040503 ✓

[illegible]