

APPLICATION No.: 7265 5/8" L load

TAP CLEARED

LOCATION: 219 Arnold St.

OWNER: Chas A. Johnson

MEASURES:	5/8"	L lead	July 23, 1892
	W from	Park	66.9 ft.
	S from N line	Arnold	6.4 ft.
	W from E line	House	13.0 ft.

May 31, 1946 Leak near tap. 2 ft. -  $5/8$ " H. lead;

Dec. 30, 1957 Renewed from a point  $\frac{1}{2}$  ft. outside curb stop to a point 2 ft. inside curb stop.  
2 $\frac{1}{2}$  ft. - 3/4" copper; 1 - 3/4" copper stop, fig. 415;  
2# wiping solder.

10/27/92: Renewed from curb stop to ins.cellar (10ft ins.prop line) Stock: 17ft 3/4" copper tubing same Caldwell stop box

8/20/92 Chap 90 project Pavao cont renewed from main to prop  
line supplied all stock & labor Stock: 26ft 3/4" copper  
tubing 1-3/4" curb stop 1-Caldwell stop box  
1-3/4x5/8 lead-cop adapt.xs 1-3/4x5/8 fig 413 Insp J Rodrigues

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

10-27-  
92

92441657

8/20/92:	TAP	REAMED
----------	-----	--------

## METER HISTORY

## CHARGE OUTS

[illegible]