

LOCATION: 44 Independent St

APPLICATION No.: 7272

TAP CLEARED

OWNER:

31-313

MEASURES: Aug 22, 1892

W X County St

405.3 ft

N X S Line Independent St

9.1 ft

E X W Line House

5.1 ft

1" Copper Service

11/17/2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 11

Distance from curb stop to meter (ft) 19

Distance from curb stop to curb face (ft) 1.0

Depth of service (ft) 3.8

Total length of new pipe installed (ft) 19

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball valve furnished: yes size 1"

Remarks: 1-3/4" union installed 1LF outside curb stop

[illegible]