

APPLICATION No.: 7330

TAP CLEARED

LOCATION: ~~54~~ 58 Katherine St.

OWNER: Antonio Soares

DATE

BEF.

AFT.

REMARKS

12-2-75

Reamed

MEASURES: 1/2"

H lead

Aug. 22, 1892

E from

Crapo St.

350.5 ft.

N from S line

Katharine St.

8.9 ft.

E from W line

house

10.5 ft.

Aug. 1, 1972 Renewed from 6" outside curb stop to 2 ft.
inside cellar.

19 1/2 ft. - 3/4" Copper tubing 3/4" curb stop
1 wipe joint Stop Box

December 2, 1975 Repaired Service leak from the
corporation tap to 6" outside the curb stop.
1 5/8" figure 413(5/8"x3/4") 1 3/4" x 3/4" cop. coup.
8.8 ft. 3/4" copper tubing
Cleared corporation tap.

[illegible]

CHARGE OUTS

[illegible]