

APPLICATION No.: 7376 5/8<sup>th</sup>

TAP CLEARED

LOCATION: 172 Coffin Ave.

OWNER: Umber Rapoza

MEASURES: 5/8"

W from

Belleville Ave.

86.1 ft.

N from S line

Coffin Ave.

9.5 ft.

E from ~~E~~ line

House

2.4 ft.

8/23/78: Franklin Const. renewed service from the main to the property line. 20 ft.-3/4" copper; 5/8" x 3/4" Fig. 413; 3/4" curb stop; Caldwell stop box; 5/8" x 3/4" lead cop. adapt. XS

7/30/04 Renewed from property line to inside cellar. (8 ft. inside property line)  
Stock: 8 ft. 3/4" copper tubing; 3/4" x 3/4" cop-cop cplg., comp.  
Note: We hooked up (see question #6 on Service leak report)

Note: We hooked up (see question #6 on Service leak report)

Note: We hooked up (see question #6 on Service leak report)

[illegible][illegible]