

APPLICATION No.: 7414 5/8" L lead

TAP CLEARED

LOCATION: ~~87-0~~ Austin St.

OWNER: Joseph C. De Mello

DATE

BEF.

AFT.

REMARKS

2/26/76

Reamed

MEASURES:	5/8"	L lead	Nov. 2, 1892
	W from	County	117.7 ft.
	S from N line	Austin	7.3 ft.
	W from E line	House	13.1 ft.

Aug. 14, 1950 Repaired leak at tap.  
 1 1" female by 3/4" cop coup. fig. 413; 1 ft. + 3/4"  
 copper tubing;

- - -

Nov. 24, 1971 Renewed from 1/2 ft. outside curb stop  
 to property line.  
 9 ft. - 3/4" Copper tubing 3/4" Hays curb stop  
 2 wipe joints - - -

March 24, 1975 Renewed from the property line to inside  
 cellar.  
 10 ft. - 3/4" Copper tubing - Work done by Owner's  
 plumber- Copper supplied by Owner

- - -

Feb. 26, 1976 Renewed from main to curb stop  
 20 ft. - 3/4" Copper tubing 3/4" curb stop  
 stop box 3/4" x 3/4" Fig. 413  
 - - -

## METER HISTORY

## CHARGE OUTS

[illegible]