

LOCATION: 98 Austin St.

OWNER: Edward M. Silva

MEASURES: 5/8" L lead  
 W from County  
 N from S line Austin  
 E from W line House

Nov. 23, 1992  
 196.1 ft.  
 6.9 ft.  
 11.6 ft.

DATE

BEF.

AFT.

REMARKS

2/25/76

Reamed

2/28

962505629

Oct. 6, 1949 Leak at tap  
 No stock used.

- - -

Jan. 25, 1971 Renewed from 1/2 ft. outside curb stop  
 to property line.  
 8 ft. - 3/4" Copper tubing 3/4" Hays curb stop  
 2 wipe joints

- - -

Feb. 25, 1976 Renewed from the main to the property  
 line.

14 ft. - 3/4" Copper tubing 3/4" curb Stop  
 Stop Box 3/4" x 3/4" Fig. 413

- - -

June 20, 1996:

Renewed from curb stop to ins. cellar (10.5ft ins. prop line)  
 Stock: 17.5ft 3/4" copper tubing same curb stop  
 same Caldwell stop box =====

## METER HISTORY

## CHARGE OUTS

[illegible]