

APPLICATION No.: 7454

LOCATION: 129 Field St

OWNER:

31-313

MEASURES:  $3/4"$  Copper

9/11/09 - Renewal - New 3/4" Measurements

|                          |       |
|--------------------------|-------|
| S from S line Babbitt St | 338.4 |
| E from W line Field St   | 6.7   |
| S from N line House      | 1.6   |
| N from S line House      | 20.0  |
| E from E line House      | 16.7  |
| Main to Property Line    | 18.0  |
| Pipe inside Property     | 12.0  |

9/11/09 - Reis Asphalt renewed service from curb stop to meter  
Owner charged \$130 (\$30 shut-off, \$70 inspection & \$30 turn-on)  
Inspected by Percy Reynolds

TAP CLEARED

DATE \_\_\_\_\_

BFF

AFT

REMARKS

[illegible]

# CHARGE OUTS



APPLICATION No.: 7454

TAP CLEARED 89-46-4854

LOCATION: Lionel P. Medeiros Et Ux

OWNER: 129 Field St.

MEASURES: 5/8" H lead Dec.8,1892

S from                  Babbitt St.      338.4 ft.

E from W line    Field St.    7.0 ft.

S from N line house 1.6 ft.

2-21-1949 New from curb stop to line

8' of 5/8" H. lead pipe

Brightman

Soares

✓ Dec. 26, 1972 Renewed from 6" outside curb stop to the property line.

7½ ft. - 3/4" Copper tubing 3/4" Hays curb stop  
2 wipe joints

11/17/89: Renewed from main to propline: Stock: 18 ft. 3/4"  
copper tubing 1-3/4" curb stop 1-Caldwell stop box  
1 - 3/4 x 5/8 lead to cop adapt. xxs 1-3/4x5/8 Fig.413

6/25/09 Very bad leak under foundation - Percy

BRADBURY-WARING, INC.

[illegible]

## CHARGE OUTS