

APPLICATION No.: 7462

TAP CLEARED ✓

LOCATION: Bullard, Cor. 358 No. Front

OWNER: Cecilia Poczatels

MEASURES:

5/8"

E from	Front	27.6
S from N line	Bullard	9.0
W from E line	House	19.7

-----  
August 21, 1950 Repaired Leak at Tap  
1 ft. of 3/4" copper tubing  
1 1" I. P. Female 3/4" cop. coup. Fig. 413  
-----

June 18, 1971 Renewed from 1/2 ft. outside curb stop to  
inside cellar.  
14 ft. 3/4" copper tubing (4 ft. inside) 1 wipe joint  
1 3/4" Hays curb stop  
-----

9/27/78: Franklin Const. renewed service from the main  
to the property line. 32ft- 3/4" copper: 3/4" curb stop  
Caldwell stop box: 5/8" x 3/4" Fig. 413; 3/4" x 3/4" cop.-cop  
adapt



## METER HISTORY

[illegible]

## CHARGE OUTS