

APPLICATION No.: 7474

TAP CLEARED I-2215-5

LOCATION: 2 Jason Court

OWNER: John R. Medeiros Et Ux

MEASURES: 1/2" - H lead Dec. 9, 1892

W from Crapo St. 80.4 ft.

N from S line Court St. 3.1 ft.

E from W line house 1.0 ft.

July 25, 1967 Plumber supplied all work and materials

✓ Renewed from property line to inside of cellar

9 ft. - 3/4" copper tubing used. Total

Checked by E. Rodrigues.

July 25, 1967 Renewed from 1/2 ft. outside curb stop to property line.

✓ 1 1/2 ft. - 3/4" Copper tubing 3/4" curb stop
cop to cop cplg. 1 wipe joint

- - -

Sept. 24, 1975 Renewed from the main to the curb stop

✓ 6 ft. - 3/4" Copper tubing 3/4" x 3/4" Fig. 413

SEP 11 1981 - Renewed 1" lead service starting 91 ft.

W x W line of Crapo to a point of 96' W x W line of Crapo.

✓ 5.0 ft. - 1" copper; 1" cop.-cop-comp. cplg; 1" x 1" lead-cop. adapt.

Nov. 27, 1990 Cut in a new 1" x 1" x 3/4" tee on the 1" small main.

Installed a 6" pc. of 3/4" copper tubing on tee with a 3/4" curb stop acting as a tap.

✓ 1" x 1" x 3/4" tee, sweat

1 - 3/4" curb stop

1 ft. - 1" copper tubing

6" - 3/4" copper tubing

2 - 1" x 1" lead to copper adaptor XXS

[illegible]

CHARGE OUTS

[illegible]

✓

[illegible]

1/15/2019 curb stop repair. Curb Stop was broken in the off position
cut and installed a new csv live w/ 1 x 3/4" copper & copper to copper
3/4 curb stop Valve .75 box of 3/4 copper tubing 3/4 copper to copper coupling
Daniel Perry-Ronnie Aguilar

[illegible]

CHARGE OUTS