

APPLICATION No.: 7552  $\frac{1}{2}$ " H lead

## TAP CLEARED

LOCATION: 199 Belleville Ave.

OWNER: Rosorein Kwezeuski

MEASURES:	$\frac{1}{2}$ "	H lead	May 6, 1893	
	N from	Beetle	<del>66.0 ft.</del>	69.0 ft.
	E from W line	Bealeville Ave.	<del>6.0 ft.</del>	7.0 ft.
	N from S line	House	<del>12.0 ft.</del>	13.0 ft.
	E x E line	House		35.7 ft.

Oct. 14, 1952 Renewed 1 ft. from tap; Tap reamed  
1 ft. - 3/4" copper tubing; 1-3/4" cop to i.p. fem.  
cplg. fig. 413;

Dec. 3, 1969 Renewed from 6" outside curb stop to the property line.  
9½ ft. - 3/4" copper tubing; 1 - 3/4" Hays curb stop;  
2 # wiping solder.

7/8/76: Due to the installation of the 48" main this service has been renewed from the main to 10 ft. from the main. Stock supplied & inst by Zoppo. 10 ft.-3/4" Copper tubing; 1" Corporation Ford compression; 1" x 3/4" Reducer; 3/4" curb stop Ford compression; 3/4" x 5/8" lead to copper adaptor XKS; Measures of 1" Corporation: N x N line

Beetle St. 69.0 ft.- E x W line Belleville Ave. 18.0 ft.

## METER HISTORY

## CHARGE OUTS

[illegible]

APPLICATION No.: 10112  $\frac{1}{2}$ " H lead

TAP CLEARED

LOCATION: 195 -201 Belleville Ave

OWNER: Louis Halm

MEASURES:  $\frac{1}{2}$ " H lead Apr. 22, 1902  
Connection of #7552 made by owner.

DATE

BEF.

AFT.

REMARKS

## METER HISTORY

## CHARGE OUTS

[illegible]