

APPLICATION No.: 7582  $\frac{2}{2}$ " H lead

TAP CLEARED

LOCATION: 184 Belleville Ave.

OWNER: Edward M. Silva

DATE

BEF.

AFT.

REMARKS

4/22/75

Reamed ✓

MEASURES:  $\frac{1}{2}$ " S H lead May 6, 1893  
 S from A line Beetle ~~5.0 ft.~~ 5.0 ft  
 W from E line Belleville Ave. ~~8.6 ft.~~ 8.6 ft  
 S from N line House ~~16.0 ft.~~ 16.0 ft  
 W x W line House 17.0 ft

May 5, 1950 New from curb stop to inside cellar.  
 20 ft. -  $\frac{3}{4}$ " copper tubing;  
 - - -

April 22, 1975 Renewed from the main to the curb stop.  
 24 ft. -  $\frac{3}{4}$ " Copper tubing Caldwell Stop Box  
 $\frac{3}{4}$ " x  $\frac{3}{4}$ " Fig. 413  $\frac{3}{4}$ " Curb Stop  
 - - -

7/7/76: Due to the installation of the 48" main this service has been  
 renewed from the main to 22 ft. from the main. Stock supplied & inst.  
 by Zoppe; 1" Corporation Ford compression; 1" x  $\frac{3}{4}$ " Reducer; 22 ft.  
 $\frac{3}{4}$ " copper tubing;  $\frac{3}{4}$ " Curb stop Ford compression;  $\frac{3}{4}$ " x  $\frac{5}{8}$ " lead  
 to copper adapt. XXS; Measures of 1" Corporation: S x S line Beetle St.  
 5.0 ft. W x E line Belleville Ave. 29.0 ft.

11/4/92: Belleville ave sewer proj: Gioioso Cont. backfilling  
 trench pulled service from curb stop Renewed from stop to a  
 point 2.3ft W x curb stop Stock: 2.3ft  $\frac{3}{4}$ " copper tubing  
 1-3/4x3/4 cop-cop cplg.comp. Insp M Rose III

## METER HISTORY

[illegible]

## CHARGE OUTS