

APPLICATION No.: 7590TAP CLEARED ✓LOCATION: 256 WeldOWNER: E. SullivanMEASURES: 3/4"

W from	Myrtle	72.3 ft.
N from S	Wld	8.7 ft.
W from E	house	8.8 ft.

April 12, 1976 Renewed from the main to the property line.

18 ft. - 3/4" Copper tubing

Stop Box

Tap reamed

3/4" Curb Stop

3/4" x 3/4" Fig. 413

3/4" x 5/8" lead connector

- - -

4/29/91 Broken by Meter room while removing meter. Inside of cellar.

Installed a 5/8" x 3/4" lead to copper adapt XXS, 1 ft. - 3/4" copper tubing

outside of meter - repaired by G. Pitta & J. Garcia

9-24-99 Renewed from property line to inside cellar.

(8 ft. - ins. prop. line.) Stock: 3 ft. - 3/4" Copper tubing, 1 - Caldwell Stop Box, 1 - 3/4" x 3/4" cop to cop cplg., comp. 9946911

DATE

BEF.

AFT.

REMARKS

4/12/76-

Reamed

9/14/99 19993706291

[illegible]

CHARGE OUTS

[illegible]