

APPLICATION No.: 7660

TAP CLEARED

8507-0009

LOCATION: 69 Tremont S.W. Cor. Arnold

OWNER: E. Brightman

MEASURES:

5/8"

W from

Tremont

53.2 ft.

N from S line

Arnold

6.4 ft.

E from W line

house

10.9 ft.

DATE

BEF.

AFT.

REMARKS

2/11/85 TAP REAMED

11/22/89: TAP REAMED

8/11/92: tap reamed

2/11/85 Renewed from main to a point 8" outside of main
 Stock: 8" 3/4" copper tubing 1 3/4x5/8 lead to cop
 adapt. 1 3/4x5/8 Fig.413

=====
 5/20/85: Renewed from 1/2' outside curb stop to ins.cellar.(5ft. ins. prop line)
 Stock: 12 ft. 3/4" copper tubing 1 3/4" curb stop
 1 Caldwell stop box 1 3/4 x 5/8 lead to cop adapt. xs

=====
 11/22/89: Renewed from main to a point 1 ft.
 Stock: 1ft. 3/4" copper tubing 1-3/4x5/8 lead to cop adapt. xs
 1 - 3/4 x 5/8 Fig.413
 =====

8/11/92: Ch 90 proj. Pavao Const. renewed from main to curb stop
 Stock: 7.5ft 3/4" copper tubing 1-3/4" curb stop
 1-Caldwell stop box 1-3/4" corp tap 1-8x3/4 service saddle(water dept)
 NOTE: OLD TAP WAS PULLED OUT OF MAIN BY CONTRACTOR.Insp J Rodrigues
 =====

[illegible]