

APPLICATION No.: 7731

TAP CLEARED

8812-0067

LOCATION: 7 Harmony St.

OWNER: John Bauer

DATE

BEF.

AFT.

REMARKS

3/22/88

reamed

MEASURES: 1/2" H lead July 31, 1893

N from Brock Ave. 114.8 ft.

E from W line Harmony St. 9.6 ft.

S from N line house 7.7 ft.

OK ELECTRIC JR.

3/22/88 Renewed from main to property line: 20ft-3/4" copper tubing
 1-3/4" curb stop, 1-Caldwell stop box, 1-5/8x3/4 lead to cop adapt xs
 1-5/8x3/4 Fig 413,

6/16/93 Shut off at curb stop Must renew with copper from
 the prop line to cellar before turning on water.

10/7/96 Muriel called - was this service renewed from prop line in?? Ramos on vaca 7/31/96
 We had no record - Alvin Ramos said he helped owner while on vaca. renew from prop line to meter. 7/3
 Checked by Meter Room 10/8/96 - there is an adaptor at wall partially covered in cement -
 appears to be a lead to copper adapt. Owner refused to chip away cement for inspection - did not
 turn water on. Pitta

10/9/96 Checked by Pitta - Owner dug under porch and renewed from prop. line to meter.
 Inspected by Pitta - OK

1/29/16: JLC Construction renewed service from curb stop to cellar
 P.Reynolds Inspected

[illegible]

CHARGE OUTS

[illegible]

7731 8129

TAP CLEARED

LOCATION: 11 Harmony St

OWNER: John Bauer

31-313

MEASURES:	NEW MEASURES
-----------	--------------

S	From		Social St	108.0
E	From	W Line	Harmony St	7.5
S	From	N Line	House	8.4

DATE _____

BEF.

AFT.

REMARKS

[illegible]