

APPLICATION No.: 7789

TAP CLEARED

LOCATION: 30 Durfee

OWNER: Arelia C. Marrsean

MEASURES:

 $\frac{3}{4}$ "

W from	Cottage	191.2
N from S line	Durfee	6.9
W from W line		1.3

Dec. 15, 1965 Renewed from 6" outside curb stop to meter inside cellar
22 $\frac{1}{2}$ ft. $\frac{3}{4}$ " coppertubing
 $\frac{3}{4}$ " cop. to cop. stop, fig. 415
1b. wiping solder

APR 20 1982 -- Renewed service from the main to the property line. 7.0 ft. $\frac{3}{4}$ " copper; $\frac{3}{4}$ " curb stop; stop box; 1" x $\frac{3}{4}$ " Fig. 413;

2/4/93: Reamed at tap only Used same material that was there but we installed 1- $\frac{3}{4}$ x $\frac{3}{4}$ copper cplg. 1ft south from main & serv tap Stock: 1- $\frac{3}{4}$ x $\frac{3}{4}$ cop-cop cplg.comp.

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

9306 1913

METER HISTORY

[illegible]

CHARGE OUTS

This image shows a blank, aged, cream-colored page, likely an endpaper or flyleaf of a book. The paper has a slightly textured appearance with some faint smudges and discoloration, characteristic of old paper. The left edge of the page shows the binding, with visible stitching and the inner cover material. There is no text or other markings on the page.