

APPLICATION No.: 7822  
LOCATION: 475 - 477 Cottage St

TAP CLEARED

DATE BEF. AFT. REMARKS

OWNER:

31-313

01/10/85

MEASURES: Oct. 12, 1893

12/21/90 Ream

S X Parker St 140.7 ft

E X W line Cottage St 7.4 ft

S X S line House 8.2 ft

1" Copper Service

03/16/2020 Lead Service Line Replacement Program

Phase 1 Contractor P.Gioioso & Son

Type CU, Diameter (in) 1, Water Pressure 50

Distance from main to curb stop (ft) 7

Distance curb stop to meter (ft) 19

Distance from curb face to curb stop (ft) 3.5

Depth of service (ft) 3.9

Total length of new pipe installed (ft) 26

Curb stop replaced : yes size 1

Corporation replaced : yes size 1"

Ball valve replaced : yes size 1"

# METER HISTORY

## CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

