

APPLICATION No.: 783

TAP CLEARED

LOCATION: 271 County St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

Aug 2, 1871

W from County St 101.0'

S from N line Washington St 6.9'

W from W line house 8.2'

June 25, 1982

10/20/1995: tap

reamed

1" COPPER SERVICE

12/10/2018: Lead service line replacement program

phase 1: Contractor: B. Gioioso & Sons

TYPE: CU, Diameter 1 inch, Water Pressure 95

Distance from main to curb stop 21'

Distance curb stop to meter 82.4'

Distance from curb face to curb stop 2.5'

Depth of service 3.8'

Total length of new pipe installed 82.4'

Curb stop replaced: NO Size 3/4"

Corporation replaced: NO Size 3/4"

Ball Valve furnished: YES Size 1"

Remarks- 1-3/4" union installed 1LF outside curb stop

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

