APPLICATION No.:7843	TAP CLEARED			
LOCATION: 89 Washington St	DATE	BEF.	AFT.	REMARKS
OWNER:				
MEASURES: E X Crapo St S X N Line Washington St W X E Line House 1" Copper Service 9/26/2018 Lead Service Line Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water pressure 80 Distance from main to curb stop (ft) 21.9 Distance from curb stop to meter (ft) 17 Distance from curb face to curb stop (ft) 1.5 Depth of service (ft) 3.8 Total length of new pipe installed (ft) 21.9 Curb stop replaced: Yes size 1" Corporation replaced: Yes size 1" Ball valve replaced: No size 3/4" Remarks: 1-3/4 union installed 1.0 lf outside curb stop				

