

TAP CLEARED

LOCATION: 49 Beetle St.

OWNER: Alice Murch

MEASURES:	5/8"	H lead	Dec. 19, 1893
	E from	Howard	13.1 ft.
	S from N line	Beetle	9.0 ft.
	E from W line	House	6.4 ft.

June 7, 1963 Renewed from 6" outside curb stop to 4 ft. inside curb stop.
4½ ft. - 3/4" copper tubing; 1 - 3/4" cop to cop stop, fig. 415; 2# wiping solder.

Dec. 2, 1969 Renewed from the main to a point 3 ft. from the main.
3 ft. - 3/4" copper tubing; 1-3/4" x 3/4" Fig. 413 cplg;
1# wiping solder; 5/8" tap reamed;

2/2/91 shut off per order Fire Dept.
meter removed 3/27/91

2/6/92 This service has been shut off for over one year - therefore must apply for new service before turning on.

METER HISTORY

CHARGE OUTS

[illegible]