

APPLICATION No.: 7933

TAP CLEARED

LOCATION: 3 Glover

OWNER: Armand J. Fournier

MEASURES:

3/4"

N from	Austin	86.6
E from W line	Glover	6.6
N from S line	House	7.5

Dec. 16, 1968 Repaired leak at the tap
1 ft. of 3/4" copper tubing 3/4" x 3/4" fig. 413 cplg.

APR 26 1982 --Tilcon renewed from the main to the prop.
line. 14.5 ft. - 3/4" copper; 3/4" curb stop; stop box;
1" x 3/4" Fig. 413; 5/8" x 3/4" lead-cop. adapt. XXS;

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

11/16/68

reamed

[illegible]

CHARGE OUTS

[illegible]