

APPLICATION No.: 7980

TAP CLEARED

9042-4140

LOCATION: 48 Smith

OWNER: Philys Lawrence

MEASURES: 3/4"

E from	Summer	144.9 ft.
N from S line	Smith	7.2 ft.
E from W line	House	1.0 ft.

9994422

 April 10, 1963 Renewed from main to curb stop including new curb stop.

8 ft. of 3/4" copper tubing 1 3/4" cop. to cop. stop
 1 3/4" reused copp. cplg. reused 1 cop. to cop. cplg. 3/4"

 February 23, 1960 Renewed from curb stop to property line.

8 ft. of 3/4" copper tubing 2 lbs. wiping solder

10/18/90: Renewed from prop line to ins. cellar

12 ft. ins. prop line Stock: 12 ft. 3/4" copper tubing

1- 3/4x3/4 cop to cop cplg. comp.=====

9/17/02 Renewed from main to a point 2 ft. from the main;
 2 ft.-3/4" copper tubing; 1-3/4x3/4 cop to cop cplg., comp.
 1-3/4x3/4 Fig.413; tap reamed; Note-Replaced at 3ft 6"PVC
 sewer service over water main

DATE

BEF.

AFT.

REMARKS

4-10-63

Reamed

9/12/02

2002 3710158

[illegible]

CHARGE OUTS

[illegible]