

APPLICATION No.: 7985

TAP CLEARED 8434-2500

LOCATION: 389 Davis St.

OWNER: George Peters

MEASURES:

W from	Church	174.6
S from N line	Davis	6.7
E from W line	House	5.2

August 24, 1984

Renewed from 1/2' outside curb stop to ins. cellar
13.0 ft. ins. prop line Stock: 21.0 ft. 3/4 copper
tubing 1 3/4 curb stop 1 #1 Caldwell stop box
1 5/8 XXS lead to cop*adapt. comp.

1" Copper Service-----

05/31/2018 Lead Service Line Replacement program
Phase 1, Contractor P Gioioso & Son

Type CU Diameter 1in Water pressure 68
Distance from main to curb stop (ft) 15.0

Distance from curb stop to meter (ft) N/A
Distance from curb face to curb stop (ft) 4.0
Depth of service (ft) 4.0

Depth of service (ft) 4.0

Total length of new pipe installed (ft) 15.0

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve furnished: no

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

7-14-5

6/5/5

