

APPLICATION No.: 8015

TAP CLEARED 8827-0039

LOCATION: 140-4 Purchase St.

OWNER: Mercantile Realty Co.

MEASURES:

~~5/8"~~ 3/4" Copper H

H lead

June 27, 1894

N from

Potomska St.

25.7 ft.

W from E line

Purchase St.

6.5 ft.

S from N line

house

3.2 ft.

January 16, 1961 Renewed from curb stop to meter in cellar.
10 ft. of 3/4" copper tubing 1 lb. solder

March 23, 1948 Leaks between tap and curb stop.
2 cup joints - 1 at tap & 1 at curb stop.

7/5/89: Renewed from main to a point 9 ft Stock: 9ft. 3/4"
copper tubing 1-3/4x5/8 lead to ccp adapt. xxs 1-3/4x5/8
Fig. 413

August 22, 1990	Renewed from a point 4 ft. outside curb stop to a point 5 ft. inside curb stop in sidewalk. Installed a 3/4" curb stop, buried - 4 ft. outside curb stop			
1 - 5/8" x 3/4" lead to copper adapt	XXS			
pc. of 3/4" copper tubing				
1 - 3/4" curb stop, buried				
4 ft. - 3/4" copper tubing				
Used existing curb stop in sidewalk & box				
5 ft. - 3/4" copper tubing - 1 - 3/4" x 3/4" cop to cop cplg.				

BRADBURY-WARING, INC.

OVER

[illegible]

CHARGE OUTS

140 APPLICATION No.: 8015

LOCATION: Potomska, N.E. cor. Purchase

OWNER:

MEASURES: 5/8"

H lead

June 7, 1894

N from Potomska

25.7

W from E line Purchase

6.5

S from N line house

3.2

TAP CLEARED

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

[illegible]

CHARGE OUTS

[illegible]