

8032

APPLICATION No.:

LOCATION: 108 Grinnell St

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

1" COPPER

July 13, 1894

W from Acushnet Ave 93.6'

N from S Line Grinnell St 6.4'

W from E line house 2.6'

6-5-2019: Lead service line replacement program  
phase 1, TYPE: CU, Diameter 1, Water Pressure 100

Distance from main to curb stop 8'

Distance curb stop to meter 19'

Distance from curb face to curb stop 2'

Depth of service 3.5'

Total length of new pipe installed 27'

Curb stop replaced: YES Size 1"

Corporation Replaced: YES Size 1"

Ball Valve furnished: YES Size 1"

6/2/58: reamed

# METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

## CHARGE OUTS

