

APPLICATION No.: 8059

TAP CLEARED

LOCATION:

113 Acushnet Ave

OWNER:

'31-313

MEASURES:

August 17, 1894

N from South St 54.4'

E from W line acushnet ave 7.0'

S from N line house 9.8'

1" COPPER SERVICE

9/6/2018: Lead service line replacement program

phase 1: Type CU: Diameter 1: Water Pressure 100

Contractor: P. Gioioso &amp; Sons

Distance from main to curb stop 11'

Distance curb stop to meter N/A

Distance from curb face to curb stop 1.5'

Depth of service 4.5'

Total length of new pipe installed 100'

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball valve furnished: NO

DATE

BEF.

AFT.

REMARKS

# METER HISTORY

## CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

