

SERVICE

Application No.

St. & No.

Size Pipe

323 Maxfield, N.E. Cor. Emerson 8070

Kind Pipe

Laid

-5/8" 3/4" E-lead Copper Aug. 25, 1894

E from Chancery St. 237.8 ft.

S from N line Maxfield St. 7.0 ft.

E from W line house St. 8.0 ft.

City

27 ft. Earth

26 ft. Pipe

Taker

ft. Earth

ft. Pipe

11 71

REMOVED 11/29/2004

Jan. 18, 1963, ser. leak, renewed from 1/2 ft. outside curb stop to property line using 7 1/2 ft. 3/4" cop. tub., 1-3/4" cop. stop, Fig. 415- R; H., 2 lbs. wiping solder, 250 compressor: 1 hr.
3-18-1963, ser. leak, renewed from main to a point 1/2 ft. outside curb stop using 19 ft. 3/4" cop. tub., 1-5/8" reused corp. cplg. A-1551, 1-3/4" cop. cplg., tap reamed, 125 comp: 1 1/2 hr.
Note: this service is new from main to the property line.

NOV. 29, 2004 - SER. SHUT OFF @ TAP, DISCONNECTED COPPER FROM TAP, REMOVED CURB STOP BOX ON SIDEWALK

REP. BY SER. # 32965