

APPLICATION No.: 8081

TAP CLEARED

LOCATION: 71 Mosher St

DATE

BEF.

AFT.

REMARKS

OWNER:

12/3/57 Ream

31-313

MEASURES: E X Crapo St 335.0 ft
S X N Line Mosher St 8.9 ft
W X E Line House 1.4 ft

1" Copper Service

07/25/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) 24

Distance from curb stop to meter (ft) 17

Distance from curb face to curb stop (ft) 1.9

Depth of service (ft) 4.5

Total length of new pipe installed (ft) 17

Curb stop replaced: no size 3/4"

Corporation replaced: no size 3/4"

Ball valve replaced: yes size 1"

Remarks: 1-3/4 union installed 1 ft outside
curb stop

[illegible]