

APPLICATION No.: 8119

TAP CLEARED



LOCATION: 57 Stowell N.S. Cor. Field

DATE BEF. AFT. REMARKS

OWNER: Alphonse Pavao

9/16/88: TAP REAMED

MEASURES: 5/8" 1 lead 10-19-1894
 N from Stowell 30.2 ft.
 E from W line Field 6.6 ft.
 N from N line House 0.5 ft.

 October 4, 1965 Renewed service from $\frac{1}{2}$ ft. outside curb stop to 4 ft.
 inside curb stop
 $4\frac{1}{2}$ ft. of $\frac{3}{4}$ " copper tubing 1 $\frac{3}{4}$ " cop. to cop. stop
 2 lbs. wiping solder

 9/9/78: Renewed 6" outside of curb stop to property line.
 $6\frac{1}{2}$ ft. - $\frac{3}{4}$ " copper; $\frac{3}{4}$ " curb stop; 2- $\frac{5}{8}$ " x $\frac{3}{4}$ " lead
 to cop. adapt. XXS; Caldwell stop box;

Leak at curb stop. both wipe
 joints leaking. Service
 comes off Field St.

 9/16/88: Renewed from main to prop line.
 Stock: 14 ft. $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ " curb stop
 1-Caldwell stop box 1- $\frac{3}{4}$ x $\frac{5}{8}$ Fig. 413

[illegible]

CHARGE OUTS

[illegible]