

8136



574 Union

S. W. Cor. Rotch

BEF.

REMARKS

Ramon F. Lauresill

9-9-52

Reamed

5/8"

Rotch

34.3 ft.

Union St.

9.6 ft.

house

10.6 ft.

change over to 3/4" from curb to cellar 3/5/70

September 9, 1952 Renewed 1 ft. from tap.

1 ft. of 3/4" copper tubing 1 3/4" x 3/4" cop. to I.P.F.cplg.

March 5, 1970 Renewed $\frac{1}{8}$ ft. outside curb stop to cellar.

15½ ft. of 3/4" copper tubing (7 ft. inside)

[illegible]

1 lb. wiping solder

6-18-98 Biszco Cont renewed service from the newly installed 10" ductile main to a point 2 ft from the main. Stock supplied by Contractor: 2 ft - 3/4" Copper tubing, 1 - 5/8" x 3/4" lead to cop. adapt. XS, 1 - 3/4" Corporation tap. Cont to maintain cut.

2-22-99 M. Pavao Const. renewed from main to prop. line.
Stock: 18 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop
1 - Caldwell Stop Box, 1 - 5/8" x 3/4" lead to cop.
adapt. XS. M. Pavao Cont. to maintain cut.

[illegible]

CHARGE OUTS

[illegible]