

2301 FRIENDLY FRUIT

APPLICATION No.: 8179

LOCATION: Purchase

OWNER:

MEASURES:

8" gate FIRE SUPPLY

N from 15 DEANE ST.

8.3

W from E line

43.7

S from S line main mill

31.0

E from E line main mill

18.6

February 13, 2018 Out and capped 8" ductile service to Sid Wainer bldg. Broke a

6" sewer and 8" storm drainpipe directly under the 8" water service.

Used an 8" plug on water main tee. 6 ft 6" PVC pipe; 2-6" clay-PVC; 6" CI or PVC/PVC;

6' 8" PVC pipe; 2-8" clay-PVC; 8" CI or PVD/PVC; 50' gal of water plug Manny W

TAP CLEARED

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]