

APPLICATION No.: 8211

TAP CLEARED

LOCATION: 360 Reed

OWNER: Mrs. Julia Simmons

MEASURES: 7"

Lead

6-15-1895

12/3/12

2012-4804985

N from

Elm

122.7 ft.

W from E line

Reed

6.3 ft.

S from N line

House

4.0 ft.

Dec. 27, 1955 Rewped joint at main - tap reamed
1 wipe joint

July 23, 1971 Renewed from 1/2 ft. outside curb stop to
a point 6 ft. inside curb stop.
6 1/2 ft. - 1" Copper tubing 1" Hays curb stop
2 wipe joint Buffalo Stop Box

August 25, 1975 Renewed from the main to a point $4\frac{1}{2}$ ft.
from the main.
 $4\frac{1}{2}$ ft. - 1" Copper tubing 1" x $1\frac{1}{4}$ " Fig. 413
1 wipe joint

9/23/08 west end water main rehab contract #4 perrina constr
renewed service from main to a point 1ft inside curb stop stock 21ft
1 copper tubing 1-1 corp tap 1-1curb stop 1-1x1 cop to cop cplg comp
insp T Ives cdm

12/5/12 - City crew renewed water service from 1/2 ft
outside curb stop to property line

6 ft - 1" copper tubing; 1 Caldwell stop box;
1 - 1" x 1" XL lead to copper adapt. Foreman: J. Medeiros

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 8211

LOCATION: 360 reed rd

OWNER:

31-313

MEASURES:

1/21/16 renewed c/s to meter

used 1" ball valve & 2 1" 90 elbow

16 ft 1" copper tubing

lead worker - manny washburn dpi

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]