

Service killed

APPLICATION No.: 8219

TAP CLEARED

Y

So. First 561

LOCATION: _____

OWNER: N.B. Inst. For Savings

MEASURES:

 $\frac{1}{2}$

S from	Potomska (west)	193.8
E from W line	First	7.0
N from S line	House	11.3

J.F. Kennedy Hwy Proj. June 6, 1984

Dow Co. renewed from main to property line.
10.0 Ft. - 3/4" copper tubing; 1 - 3/4" curb stop;
1 stop box; 1 - 3/4" Corp. Tap;
1 - 5/8" x 3/4" lead to copper adaptor XXS

3/3/2011 Mike Andrade killed this service at the Property line. Inspected by Mike Andrade

[illegible]

CHARGE OUTS

[illegible]