

APPLICATION No.: 8248

32 Acushnet Ave

TAP CLEARED ✓

LOCATION:

OWNER:

31-313

MEASURES:

S from Blackmet St 186.8'

W from E Line Acushnet Ave 7.3'

N from N line #30 9.0'

1"COPPER

5-14-2019: Lead service line replacement program

phase 1: TYPE CU, Diameter 1, Water Pressure 100

Contractor P. Gioioso & Sons

Distance from main to curb stop 21.4'

Distance curb stop to meter 14'

Distance from curb face to curb stop 2.0'

Depth of service 4.3'

Total length of new pipe installed 21.4'

Curb stop replaced:yes size 1"

Corporation replaced:yes size 1"

Ball valve furnished: no size 3/4"

remakrs 1-3/4" union installed 1ft outside curb stop

DATE

BEF.

AFT.

REMARKS

8-20-99 Tap reamed

[illegible]